

WELL LOCATION


CONSTRUCTION DETAILS

County Greene Township Miami
 Owner/Builder Arnovitz Enterprises Inc.
 Address of Well Location 253 Dayton Yellow Springs Rd
 City Xenia Zip Code +4 45385
 Permit No. 988770 Section/Lot No.
 Location of Well in State Plane coordinates, if available: Use of Well Domestic
 N X N 39° 47' 38.3" +/- 31' ft. or m
 S Y W 083° 54' 57.2" +/- 31' ft. or m
 Elevation of Well 910' +/- 31' ft. or m
 Datum Plain: NAD27 NAD83 Elevation Source GPS
 Source of Coordinates: GPS Survey Other

Rotary Cable Augered Driven Other
BOREHOLE/CASING (measured from ground surface)
 1 Borehole Diameter 7 1/8 inches Depth 24 ft.
 Casing Diameter 3 in. Length 24 ft. Thickness 126 in.
 2 Borehole Diameter 9 1/8 inches Depth ft.
 Casing Diameter in. Length ft. Thickness in.
 Casing Height Above Ground 1 ft.
 Type 1 Steel 1 Galv. 1 PVC 1 Other
 2 Steel 2 Galv. 2 PVC 2 Other
 Joints 1 Threaded 1 Welded 1 Solvent 1 Other
 2 Threaded 2 Welded 2 Solvent 2 Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:
 North

SCREEN
 Diameter Slot Size Screen Length ft.
 Type Material
 Set Between ft. and ft.
GRAVEL PACK (Filter Pack)
 Material/Size Volume/Weight Used
 Method of Installation
 Depth: Placed FROM ft. TO ft.
GROUT
 Material Bentonite Volume/Weight Used 35 gals.
 Method of Installation Tremie pipe
 Depth: Placed FROM 24 ft. TO 0 ft.



DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.
 Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Clay	0	4
Clay & Gravel	4	15
Limestone	15	28
Shale	28	60

water @ 28'

WELL TEST*
 Pre-Pumping Static Level 11 ft. Date 1-27-10
 Measured from: Top of Casing Ground Level Other
 Air Bailing Pumping* Other
 Test Rate 6 gpm Duration of Test 2 hrs.
 Feet of Drawdown 49 ft. Sustainable Yield 6 gpm
 *(Attach a copy of the pumping test record, per section 1521.05, ORC)
 Is Copy Attached? Yes No Flowing Well? Yes No
 Quality Clear

PUMP/PITLESS
 Type of pump Capacity gpm
 Pump set at 45 ft. Pitless Type
 Pump installed by
 I hereby certify the information given is accurate and correct to the best of my knowledge.
 Drilling Firm Hamilton & Sons
 Address 444 Milton Carlisle Rd.
 City, State, Zip New Carlisle, OH 45344
 Signed Shirley Hamilton Date 1-27-10
 ODH Registration Number 0032

*(If more space is needed to complete drilling log, use next consecutively numbered form.)
 Date of Well Completion 1-27-10 Total Depth of Well 60 ft.